

Pipe Hangers

Pipe hangers are used to support a sprinkler piping system from the building structure. Two or more listed components may be required to form a complete hanger. The specific components required depend upon the type of building construction and the pipe size.

Pipe Hangers

Product Designation	Hanger Rod Size, mm	Component Description	For Nominal Pipe Size, in.	
MP-SP	10	Loop Hanger	3/4 through 4	
	12	· ·	133 mm through 6	
	16	"	219 mm	
MP-MS	10	Pipe Clamp Hanger	68/72 through 4	
MP-MS2	12	"	133 mm through 6	
	16	"	219 mm	
MF-SKD-M10	10	Toggle	3/4 through 1 1/2	
MF-TSH-M10	10	Suspension Hanger	3/4 through 2	
LH 3/4	3⁄8	Loop Hanger	3⁄4	
LH 1	3⁄8	"	1	
LH 1 1/4	3⁄8	· ·	1 1⁄4	
LH 1-1/2	3⁄8	· ·	1 1/2	
LH 2	3⁄8	"	2	
LH 2 1/2	3⁄8	"	2 1/2	
LH 3	3⁄8	"	3	
LH 4	3⁄8	"	4	
LH 6	1/2	"	6	
LH 8	1/2	"	8	
BC-WM 3/8	3⁄8	Beam Clamp	3/4 through 4	
BC-WM 1/2	1/2	"	3/4 through 8	
BC 3/8	3⁄8	Beam Clamp	3/4 through 4	
BC 1/2	1/2	"	3/4 through 8	
SDC-EG 2 1/2	1/2	Clevis Hanger	2 1/2	
SDC-EG 3	1/2	"	3	
SDC-EG 4	5⁄8	"	4	
SDC-EG 5	5⁄8	"	5	



SDC-EG 6	3⁄4	6
SDC-EG 8	3⁄4	8
		Metric only or English only or Primary/secondary

Product Designation	Hanger Rod Size, mm	Component Description	For Nominal Pipe Size, in.
00257366	3⁄8 (10)	Beam Clamp	3/4 through 4
00306600	3⁄8 (10)	Beam Clamp	3/4 through 4
00257367	1/2 (12)	Beam Clamp	5 through 8
00306601	1/2 (12)	Beam Clamp	5 through 8
00306602	3⁄8 (10)	Beam Clamp	3/4 through 4
00306603	1/2 (12)	Beam Clamp	5 through 8

Company Name:	Hilti Inc		
Company Address:	5400 S 122nd East Ave, Tulsa, Oklahoma 74146, USA		
Company Website:	http://www.hilti.com		
Listing Country:	United States of America		
Certification Type:	FM Approved		